VYBO) Elec	tric a.	s.					
Data Sheet Three Phase Induction Motor				No. Drawing No.			30	
							tric	
Customer			<u> </u>					
Client reference					I			
Type 2LC-315L 2-2				00/690V 50H	Z			
Brand VYBO Electric								
2.0.10	10.50		tification					
Гуре:	2LC-31	15L 2-2	Frame:		1 3	315	mm	
Power:	200	kW	Poles:		2 P			
Rated Current: 400 V	334	A	Rated Volt	age:	400	/ 69		
Speed:	2975	rpm	Connection		400	/ 03 △/Y	0 V	
requency:	50	Hz	Insulation (F		
Direct on line starting torque ratio (LRT/RLT):		2	Temperature Rise:					
Direct on line pull out torque ratio (BDT/RLT):	2,2		Service Factor:		1,0			
Direct on line starting current ratio (LRA/RLA):	7,1		Duty:		S1, S2, S3, S4-S9			
Efficiency:	95	, %	Ambient Temperature:		-35~50°C (On request possible 62°			
emiciency: Power factor:		<u> %</u> ,91	Ambient Temperature: Altitude:		-35~50°C (On request possible 62°			
Noise level:	92	dB(A)	Protection Degree:		1000m IP55			
voise ievei.	92	ub(A)	Cooling:		IC411 IM B (On request)			
				Mounting:		2.8 mm/s		
				Vibration: Direction of Rotation:		2.8 mm/s Both		
						DOL or VFD		
				Starting Method: Coupling:		DOL or VFD DIRECT Parabolic or linear curve		
			Load Type:		2-M63X1.5			
			Terminal b		enin er lede ver		.5	
- 44				De	aring Inform	ation	NDE	
					DE		NDE	
			Bearing:		6317C3		6317C3	
				Regreasing int.(h):				
				Grease amount(g):				
			Grease:					
Notes / Accessories				S	Deviation Sh	eet		
				VYBO Electric		Customer		
			1					
Standards			•					
Specification: IEC60034-1 / GB755								
Test: IEC60034-2								
Test: IEC60034-2 / GB/T1032 Noise: IEC60034-9 / GB10069.3 Vibration: IEC60034-14 / GB10068 Edition Performed Checked Date								
				WP.	- Same	A Think		
				-	-			
r enormed Check	NGU	-	Jaio			1		
Item Changes				Performed	Checke	d I	Date	
Rein Changes				renormed	Checke	u	Dale	
- 						-		