| VYBC |) Elec | tric a. | s. | | | /. | $\overline{}$ | | |
|--|----------|-------------------------|----------------------|-----------------|---------------------------|--------------|---------------|--|--|
| Data Sheet No. | | | | | — (V | | 730 ectric | | |
| Three Phase Induction Motor | | | | Drawing No. | | | ectric | | |
| Customer | | | | | | | | | |
| Client reference | | | | | | | | | |
| Type 3LC-225M-2 4 | | | | 390V 50HZ | | | | | |
| Brand | | | | | | | | | |
| Sidila . | 14.50 |) Electric | tification | | | | | | |
| Туре: | 3l C-2 | 25M-2 | Frame: | | | 225 | mm | | |
| Power: | 45 | kW | Poles: | | 2 | | P | | |
| Rated Current: 400 V | 76,8 | A | Rated Volta | ge: | 400 | | 90 V | | |
| Speed: | 2970 | rpm | Connection | | .00 | <i>,</i> △/Y | | | |
| requency: | 50 | Hz | Insulation C | | | F | | | |
| Direct on line starting torque ratio (LRT/RLT): | | 2 | Temperature Rise: | | | | | | |
| Direct on line pull out torque ratio (BDT/RLT): | 2,3 | | Service Factor: | | 1,0 | | | | |
| Direct on line starting current ratio (LRA/RLA): | 7,7 | | Duty: | | S1, S2, S3, S4-S9 | | | | |
| Efficiency: | 94 | % | Ambient Temperature: | | -35∼40°C | | | | |
| Power factor: | 0 | ,9 | Altitude: | | 1000m | | | | |
| Noise level: | 86 dB(A) | | Protection Degree: | | | IP55 | | | |
| | 7 | | | Cooling: | | | IC411 | | |
| | | | | | IM B (On request) | | | | |
| | | | Vibration: | | | 2.8 mn | n/s | | |
| | | | Direction of | Rotation: | | Both | | | |
| | | | Starting Method: | | DOL or VFD | | | | |
| | | Cou | | | | DIRECT | | | |
| | | | Load Type: | | Parabolic or linear curve | | | | |
| | | Terminal box: 2-M50X1.5 | | | | | | | |
| | | | | Bea | ring Inforn | nation | | | |
| | | | | | DE | | NDE | | |
| | | | Bearing: | | 6313C | 3 | 6313C3 | | |
| | | | Regreasing int.(h): | | | | | | |
| | | | Grease amount(g): | | | | | | |
| 1 1 | | | Grease: | S.1 | .0. | | | | |
| Notes / Accessories | | | | Deviation Sheet | | | | | |
| | VYBO | /BO Electric Customer | | | ner | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| Standards | | | | | | | | | |
| Specification: IEC60034-1 | | | 4 | | | | | | |
| Test: IEC60034-2 | / GB/T1 | 032 | | Salara Salara | | Al . W | | | |
| se: IEC60034-9 / GB10069.3 | | | | | 1° 382 100 | | | | |
| Vibration: IEC60034-14 | / GB10 | 068 | | | | | | | |
| Edition | | | | | - Simme | | | | |
| Performed Check | ked | | Date | | | _ | 1 17 | | |
| | | | | | | | | | |
| Item Changes | | | | Performed | Check | ed | Date | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |